

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OC101		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner SCHLUTTER, JON						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 9751 CTY HWY K						Town of LANARK											
City AMHERST						State WI		Zip Code 54406				Street Address or Road Name and Number 9751 CTY HWY K					
County Portage		Co. Permit #		Notification #		Completed 11-27-2000		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) ROBERT PETRICK				Lic. # 125		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.36651 °N -89.30636 °W							
Address 1460 MAPLE ALMOND WI 54909				Well Plan Approval #				NE SE		Section 20		Township 22 N					
				Approval Date (mm-dd-yyyy)				Range 10 E									
Hicap Permanent Well #				Common Well #		Specific Capacity 6				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method								8. Geology									
Dia. (in.) 6		From (ft.) Surface		To (ft.) 106		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)			
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				I TOPSOIL		Surface		3			
										S G SAND & ROCK		3		40			
										Y SAND & GRAVEL		40		110			
6. Casing, Liner, Screen								9. Static Water Level				11. Well Is					
Dia. (in.) 6		Material, Weight, Specification Manufacturer & Method of Assembly IBSCO A53B T&C 21'				From (ft.) Surface		To (ft.) 106		80 ft. below ground surface				12 in. above grade			
Dia. (in.) 5.875		Screen type, material & slot size FLUSH 12 SLOT SS				From (ft.) 106		To (ft.) 110		10. Pump Test Pumping level 83 ft. below surface Pumping at 18 GP M for 48 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material Method								12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?									
Kind of Sealing Material		From (ft.) Surface		To (ft.)		# Sacks Cement											
13. Constructor / Supervisory Driller BP Drill Rig Operator								Lic #		Date Signed 11-27-2000							
								Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		63	Building Overhang		15
			Septic or Holding, or POWTS Tank		40

Comment:

Created On: 01-17-2001

Updated On: 08-23-2022

Review Status: