

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OC112		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A						
Property Owner BEHN, LARRY					Phone # (715)366-4067		1. Well Location				Fire # (if avail.)					
Mailing Address 10564 2ND AVE							Town of BELMONT									
City ALMOND					State WI		Zip Code 54909									
County Portage		Co. Permit #		Notification #		Completed 10-25-2001		Subdivision Name				Lot # 1				
								Block #								
Well Constructor (Business Name) ROBERT PETRICK					Lic. # 125		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.28189 °N -89.25654 °W				Method Code GPS008			
Address 1460 MAPLE ALMOND WI 54909					Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE NW		Section 23		Township 21 N		Range 10 E	
Hicap Permanent Well #			Common Well #			Specific Capacity 4			2. Well Type New Well							
									of previous unique well #				constructed in			
									Reason for replaced or reconstructed well ?							
									Construction Type Drilled							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes														Hicap Well ? No Hicap Property ? No Hicap Potable ?		
4. Potential Contamination Sources - ON REVERSE SIDE																
5. Drillhole Dimensions and Construction Method																
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock						
4		Surface		80												
						Rotary - Mud Circulation										
						Rotary - Air										
						Rotary - Air & Foam										
						Drill-Through Casing Hammer										
						Reverse Rotary										
						Cable-tool Bit ___ in. dia...										
Yes						No										
						Dual Rotary										
						Temp. Outer Casing ___ in. dia										
						Removed? ___ depth ft. (If NO explain on back side)										
8. Geology																
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
- - I -				TOPSOIL				Surface		3						
- N S -				FINE SAND				3		58						
- A S -				COARSE SAND				58		85						
6. Casing, Liner, Screen																
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level						
4		ASMA A53B T&C IBSCO				Surface		80		55 ft. below ground surface						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test						
3.875		JOHNSON SS 10 SLOT				80		85		Pumping level 58 ft. below surface						
										Pumping at 12 GP M for 48 Hrs.						
										Pumping Method ?						
7. Grout or Other Sealing Material																
Method																
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		11. Well Is						
				Surface						12 in. above grade						
Filled & Sealed Well(s) as needed?																
12. Notified Owner of need to fill & seal ?																
Filled & Sealed Well(s) as needed?																
13. Constructor / Supervisory Driller										Lic #		Date Signed				
Drill Rig Operator										Lic or Reg #		Date Signed				
BP												10-27-2001				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Building Overhang		18
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 11-28-2001

Updated On: 08-25-2022

Review Status: