

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OE234		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner MOLL, LARRY					Phone # (608)462-2210		1. Well Location				Fire # (if avail.)	
Mailing Address MOHNS RD					Town of PLYMOUTH							
City ELROY					State WI		Zip Code 53929					
County Juneau		Co. Permit #		Notification #		Completed 09-29-2002		Street Address or Road Name and Number MOHNS RD				
Subdivision Name				Lot #		Block #						
Well Constructor (Business Name) AAA QUAL WD/DIV WE TRKING HILLSBORO				Lic. # 6723		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				
Address S1595 SCENIC DR HILLSBORO WI 54634				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 31 15 N 2 E		2. Well Type New Well				
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1		of previous unique well # constructed in				
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ?				
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type						
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology			
8.75 Surface 63			Rotary - Mud Circulation			Rotary - Air			Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...			
6 63 160			Rotary - Air & Foam			Drill-Through Casing Hammer			- V C - CLAY (NON CAVING) Surface 8			
5 160 300			Yes Reverse Rotary			Cable-tool Bit ___ in. dia...			T - N - SANDSTONE BROWN 8 40			
			Yes Dual Rotary			Temp. Outer Casing ___ in. dia			T - N - SAND STONE L BROWN 40 120			
			Yes Removed? 4depth ft. (If NO explain on back side)						R - H - SHALE RED 120 126			
									E - H - SHALE GREEN 126 180			
									T - N - SANDSTONE L BROWN 180 220			
									G - N - SANDSTONE GREY 220 270			
									I - N - SANDSTONE WHITE 270 300			
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		
6		NEW P.E. A53B GRADE STL CASING 18.97# PER FT WELL THICKNESS BUTT TO BUTT WELDED				Surface		63		215 ft. below ground surface		
5		NEW P.E. SAWHILL GRADE STL CASING BUTT TO BUTT WELDED 6.0 DRIVE SHOE WELDED				58		160		11. Well Is		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		12 in. above grade		
										Developed ? Yes		
										Disinfected ? Yes		
										Capped ? Yes		
7. Grout or Other Sealing Material												
Method 1 INCH OUTSIDE TREMMIE PIPE												
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test		
NEAT CEMENT PRESURE GROUTED				Surface		63		25 S		Pumping level 280 ft. below surface		
Pumping at 8 GP M for 2 Hrs.												
Pumping Method ?												
12. Notified Owner of need to fill & seal ?												
Filled & Sealed Well(s) as needed?												
13. Constructor / Supervisory Driller								Lic #		Date Signed		
GNP												
Drill Rig Operator								Lic or Reg #		Date Signed		
DS										09-29-2002		

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		15

Comment:

Created On: 11-26-2002

Updated On: 07-30-2003

Review Status: