Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OE234

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MOLL, LARRY			Phone #: (608)462-2210
Mailing Address: MOHNS RD			
City: ELROY	State: WI	Zip Code: 53929	
County: Juneau	Co. Permit #:	Notification #:	Completed: 09-29-2002

1. Well Location
Town of PLYMOUTH
Fire # (if avail.)
Street Address or Road Name and Number: MOHNS RD
Subdivision Name | Lot # | Block #

Well Constructor (Business Name): AAA QUAL WD/DIV WE TRKING HILLSBORO	Lic. #: 6723	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code
Address: S1595 SCENIC DR HILLSBORO WI 54634		Well Plan Approval #	SW SW or Govt Lot # — Section: 31 — Township: 15 N — Range: 2 E
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.1	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	63
6	63	160
5	160	300

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Yes — Rotary - Air & Foam ..... — No
- Drill-Through Casing Hammer
- Yes — Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing ____in. dia
- Yes — Removed? 4depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	V	C	-	CLAY (NON CAVING)	Surface	8
T	-	N	-	SANDSTONE BROWN	8	40
T	-	N	-	SAND STONE L BROWN	40	120
R	-	H	-	SHALE RED	120	126
E	-	H	-	SHALE GREEN	126	180
T	-	N	-	SANDSTONE L BROWN	180	220
G	-	N	-	SANDSTONE GREY	220	270
I	-	N	-	SANDSTONE WHITE	270	300

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW P.E. A53B GRADE STL CASING 18.97# PER FT WELL THICKNESS BUTT TO BUTT WELDED	Surface	63
5	NEW P.E. SAWHILL GRADE STL CASING BUTT TO BUTT WELDED 6.0 DRIVE SHOE WELDED	58	160
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
215 ft. below ground surface

10. Pump Test
Pumping level 280 ft. below surface
Pumping at 8 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

7. Grout or Other Sealing Material
Method 1 INCH OUTSIDE TREMMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT PRESURE GROUTED	Surface	63	25 S

13. Constructor / Supervisory Driller	Lic #	Date Signed
GNP		
Drill Rig Operator	Lic or Reg #	Date Signed
DS		09-29-2002

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		15

Comment:

Created On: 11-26-2002 Updated On: 07-30-2003 Review Status: