

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OE604		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner ROERDINK, RYAN						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address N3218 SCHOOL ST						Town of LIMA							
City SHEBOYGAN FALLS						State WI		Zip Code 53085				Street Address or Road Name and Number N3218 SCHOOL ST	
County Sheboygan		Co. Permit #		Notification #		Completed 09-16-2000		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) ERWIN W FRITSCH				Lic. # 397		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.6565 °N -87.8298 °W				Method Code GCD013	
Address 2337 STAHL RD SHEBOYGAN WI 53081				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 26 14 N 22 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 1.2									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock					
10		Surface		20									
6		20		117									
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
C		CLAY		Surface		14							
S		SAND		14		22							
C		CLAY		22		45							
S		SAND		45		80							
C		CLAY		80		92							
P		HARDPAN		92		107							
L		LIMESTONE ROCK		107		117							
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		NEW BLACK STEEL PIPE T&C 19.45 280 ASTMA53 SAWHILL				Surface		107					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
CLAY SLURRY				Surface		20							
9. Static Water Level													
23 ft. below ground surface													
10. Pump Test													
Pumping level 36 ft. below surface Pumping at 16 GP M for 12 Hrs. Pumping Method ?													
11. Well Is													
14 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller								Lic #		Date Signed			
EWF										09-25-2000			
Drill Rig Operator								Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		30	Collector Sewer - San or Storm		92
Building Overhang		13	Downspout/Yard Hydrant		15
Clearwater Sump		58	Foundation Drain to Clearwater		21
			Sewer - Building Sanitary		53

Comment:

Created On: 10-17-2000

Updated On: 10-09-2019

Review Status: