Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OE604

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROERDINK, RYAN			Phone #
Mailing Address: N3218 SCHOOL ST			
City: SHEBOYGAN FALLS	State: WI	Zip Code: 53085	
County: Sheboygan	Co. Permit #	Notification #	Completed: 09-16-2000

1. Well Location

Town of LIMA

Fire # (if avail.)

Street Address or Road Name and Number: N3218 SCHOOL ST

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ERWIN W FRITSCH	397	

Address: 2337 STAHL RD, SHEBOYGAN WI 53081

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Latitude / Longitude in Decimal Degree (DD)				Method Code
43.6565 °N	-87.8298 °W			GCD013

NW NE or Govt Lot #	Section	Township	Range
	26	14 N	22 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.2

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	117

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	14
S	SAND	14	22
C	CLAY	22	45
S	SAND	45	80
C	CLAY	80	92
P	HARDPAN	92	107
L	LIMESTONE ROCK	107	117

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL PIPE T&C 19.45 280 ASTMA53 SAWHILL	Surface	107
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

23 ft. below ground surface

10. Pump Test

Pumping level 36 ft. below surface

Pumping at 16 GP M for 12 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
EWF		09-25-2000
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		30	Collector Sewer - San or Storm		92
Building Overhang		13	Downspout/Yard Hydrant		15
Clearwater Sump		58	Foundation Drain to Clearwater		21
			Sewer - Building Sanitary		53

Comment:

Created On: 10-17-2000 Updated On: 10-09-2019 Review Status: