

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OE606		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner CZYSH, MICHAEL						Phone # (920)564-6026		1. Well Location				Fire # (if avail.)							
Mailing Address N3352 ST RD 32						Town of W HOLLAND													
City SHEBOYGAN FALLS						State WI		Zip Code 53085				Street Address or Road Name and Number W3964 DEKKER RD							
County Sheboygan		Co. Permit #		Notification #		Completed 02-27-2001		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) ERWIN W FRITSCH				Lic. # 397		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.6254 °N -87.8924 °W				Method Code GCD013							
Address 2337 STAHL RD SHEBOYGAN WI 53081				Well Plan Approval # Approval Date (mm-dd-yyyy)		SE NW		Section 5		Township 13 N		Range 22 E							
						or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 1.6		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
3. Well serves 1 # of				Hicap Well ? No															
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock									
10		Surface		15															
6		15		215		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				No									
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		50 ft. below ground surface				14 in. above grade					
6		NEW BLACK STEEL PIPE T&C 19.45 .280 ASTM A-53 SAWHILL				Surface		111		10. Pump Test Pumping level 60 ft. below surface Pumping at 16 GP M for 15 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?					
Method														Filled & Sealed Well(s) as needed?					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
CLAY SLURRY				Surface		15													
13. Constructor / Supervisory Driller								Lic #		Date Signed									
EWF										03-06-2001									
Drill Rig Operator								Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120	Foundation Drain to Clearwater		48
Building Drain - Sanitary		70	Wastewater Sump		70
Building Overhang		39	Sewer - Building Sanitary		72
Clearwater Sump		88	Septic or Holding, or POWTS Tank		100

Comment:

Created On: 06-26-2001

Updated On: 10-09-2019

Review Status: