Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OG680

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BERRIG, CHRIS			Phone #: (715)258-2112
Mailing Address: 10196 HWY 54			
City: AMHERST	State: WI	Zip Code: 54406	
County: Portage	Co. Permit #:	Notification #:	Completed: 08-13-2000

Well Constructor (Business Name): VETTER WATER SYSTEMS	Lic. #: 6520	Facility ID # (Public Wells):	
Address: E808 MYNARD RD WAUPACA WI 54981		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.4	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of LANARK

Fire # (if avail.)

Street Address or Road Name and Number: 10196 HWY 54

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.3544 °N	-89.2751 °W			GCD013
NE NW or Govt Lot #	Section: 27	Township: 22 N	Range: 10 E	

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	182

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Air .....
Rotary - Mud Circulation .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	120
		C		CLAY	120	160
	W	G		WATER BEARING GRAVEL	160	182

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.625 X 280 WALDED JOINT SAWHILL	Surface	178
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	#15 SLOT	178	182

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
50 ft. below ground surface

10. Pump Test
Pumping level 150 ft. below surface
Pumping at 40 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
SH		09-09-2000
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
WV		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Building Overhang		10
			Septic or Holding, or POWTS Tank		30

Comment:

Created On: 10-03-2000 Updated On: 05-07-2020 Review Status: