

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OG680		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner BERRIG, CHRIS						Phone # (715)258-2112		1. Well Location				Fire # (if avail.)			
Mailing Address 10196 HWY 54						Town of LANARK						Street Address or Road Name and Number			
City AMHERST						State WI		Zip Code 54406				10196 HWY 54			
County Portage		Co. Permit #		Notification #		Completed 08-13-2000		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) VETTER WATER SYSTEMS				Lic. # 6520		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.3544 °N -89.2751 °W				Method Code GCD013	
Address E808 MYNARD RD WAUPACA WI 54981				Well Plan Approval #				NE NW		Section 27		Township 22 N		Range 10 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		2. Well Type Replacement									
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
						Hicap Property ? No									
						Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) 6		From (ft.) Surface		To (ft.) 182		Upper Enlarged Drillhole				Lower Open Bedrock					
						Rotary - Mud Circulation									
						<u>Yes</u> Rotary - Air									
						Rotary - Air & Foam									
						Drill-Through Casing Hammer									
						Reverse Rotary									
						Cable-tool Bit ___ in. dia...									
						Dual Rotary									
						Temp. Outer Casing ___ in. dia									
						Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)									
S		SAND		Surface		120									
C		CLAY		120		160									
W G		WATER BEARING GRAVEL		160		182									
6. Casing, Liner, Screen															
Dia. (in.) 6		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) Surface		To (ft.) 178							
Dia. (in.) 6		Screen type, material & slot size #15 SLOT				From (ft.) 178		To (ft.) 182							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material		From (ft.) Surface		To (ft.)		# Sacks Cement									
Filled & Sealed Well(s) as needed? Yes															
9. Static Water Level															
50 ft. below ground surface															
10. Pump Test															
Pumping level 150 ft. below surface															
Pumping at 40 GP M for 1 Hrs.															
Pumping Method ?															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
Lic #		Date Signed													
SH		09-09-2000													
Drill Rig Operator		Lic or Reg #		Date Signed											
WV															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Building Overhang		10
			Septic or Holding, or POWTS Tank		30

Comment:

Created On: 10-03-2000

Updated On: 05-07-2020

Review Status: