Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OG692

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BLOHOWIAK, AMY			Phone #: (920)986-3572
Mailing Address: N6106 BOELTER RD			
City: SHIOCTON	State: WI	Zip Code: 54170	
County: Outagamie	Co. Permit #:	Notification #:	Completed: 02-05-2001

Well Constructor (Business Name): VETTER WATER SYSTEMS	Lic. #: 6520	Facility ID # (Public Wells):	
Address: E808 MYNARD RD WAUPACA WI 54981		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of BOVINA				Fire # (if avail.): N6106
Street Address or Road Name and Number: BOELTER RD				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 44.4609 °N -88.6154 °W				Method Code: GCD013
SW SW or Govt Lot #	Section: 18	Township: 23 N	Range: 16 E	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	202

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	40
-	-	C	-	CLAY	40	100
-	N	S	-	FINE SAND	100	180
-	B	N	-	BROKEN SANDTSONE	180	202

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.625 X 280 WELDED JOINT SAWHILL	Surface	199
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	#12 SLOT	199	202

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface		

9. Static Water Level
5 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 20 GP M for 6 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
WV		02-05-2001
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		12	Septic or Holding, or POWTS Tank	>	40

Comment:

Created On: 06-29-2001 Updated On: 11-20-2019 Review Status: