

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OI954		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner HAGEN, CURT						Phone # (715)658-1703		1. Well Location				Fire # (if avail.)							
Mailing Address N11284 570TH						Town of SHERIDAN													
City MENOMONIE						State WI		Zip Code 54772											
County Dunn		Co. Permit #		Notification #		Completed 12-02-2001		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) OLSON BROS WELL DRILLING CO INC				Lic. # 146		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address 4625 OLSON DR EAU CLAIRE WI 54703-9714				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 20 31 N 13 W													
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 0.3				2. Well Type New Well							
Hicap Property ? No				Hicap Potable ?		Reason for replaced or reconstructed well ?													
3. Well serves 1 # of HOME				Private, potable		Heat Exchange ___ # of drillholes				Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		36						T - C S		BROWN CLAY & SAND		Surface		13			
6		36		143		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>No</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				T - N -		BROWN SANDSTONE		13		45			
										E - N C		GREEN SANDSTONE CLAY		45		63			
										T - N -		TAN SANDSTONE		63		138			
										G - N C		LT GRAY SANDSTONE & CLAY		138		143			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		86 ft. below ground surface				16 in. above grade					
6		A53B USA PRIME .280 WALL P.E. CASING WELDED 18.97# PER FT. SAWHILL				Surface		36		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 118 ft. below surface				Disinfected ? Yes					
										Pumping at 10 GP M for 1 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method TREMIE PUMPED												Filled & Sealed Well(s) as needed? No							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		NA									
NEAT CEMENT				Surface		36		13 S											
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												CJO						12-12-2001	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Sewer - Building Sanitary	>	30
Building Overhang		15	Septic or Holding, or POWTS Tank	>	60

Comment:

Created On: 02-06-2002

Updated On: 02-06-2002

Review Status: