Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OI954

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HAGEN, CURT	Phone #: (715)658-1703
Mailing Address: N11284 570TH	
City: MENOMONIE	State: WI — Zip Code: 54772
County: Dunn	Co. Permit #:
Notification #	Completed: 12-02-2001
Well Constructor (Business Name): OLSON BROS WELL DRILLING CO INC	Lic. #: 146
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 4625 OLSON DR EAU CLAIRE WI 54703-9714	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #
Specific Capacity: 0.3	

1. Well Location

Town of SHERIDAN

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

SE or Govt Lot #	SE	Section: 20	Township: 31 N	Range: 13 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	36
6	36	143

Upper Enlarged Drillhole — Lower Open Bedrock

Rotary - Mud Circulation .....

Yes Rotary - Air ..... No

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	C	S	BROWN CLAY & SAND	Surface	13
T	-	N	-	BROWN SANDSTONE	13	45
E	-	N	C	GREEN SANDSTONE CLAY	45	63
T	-	N	-	TAN SANDSTONE	63	138
G	-	N	C	LT GRAY SANDSTONE & CLAY	138	143

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53B USA PRIME .280 WALL P.E. CASING WELDED 18.97# PER FT. SAWHILL	Surface	36
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

86 ft. below ground surface

10. Pump Test

Pumping level 118 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	36	13 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
CJO		12-12-2001
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Sewer - Building Sanitary	>	30
Building Overhang		15	Septic or Holding, or POWTS Tank	>	60

Comment:

Created On: 02-06-2002 Updated On: 02-06-2002 Review Status: