

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OJ072		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner VLASAK, CHUCK						Phone # (608)462-5994		1. Well Location				Fire # (if avail.)							
Mailing Address OWL AVE						Town of GLENDALE						Street Address or Road Name and Number OWL AVE							
City ELROY				State WI		Zip Code 53929													
County Monroe		Co. Permit #		Notification #		Completed 09-09-2000		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) JIM PARKHURST JR				Lic. # 320		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address 28700 OTTOMAN AV ELROY WI 53929-9801				Well Plan Approval #		NE SW Section Township Range or Govt Lot # 25 15 N 1 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 10		3. Well serves 1 # of FARM Private, potable Heat Exchange ___ # of drillholes													
Hicap Well ? No Hicap Property ? No Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		35		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 6in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		- - C - I H N -		CLAY		Surface		15					
6		35		125						HARD WHITE SAND ROCK		15		125					
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		51 ft. below ground surface				12 in. above grade					
6		NEW STEEL 18.97 SAWHILL A53 WELDED				Surface		35		10. Pump Test Pumping level 52 ft. below surface Pumping at 10 GP M for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method PUMPED												Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		NEAT CEMENT Surface 35 12 S											
Method PUMPED												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												JP				09-09-2000			
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		12
			Septic or Holding, or POWTS Tank		63

Comment:

Created On: 03-14-2002

Updated On: 03-14-2002

Review Status: