

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OJ581		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner COLLIER, DON						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 1271 HUBERTS DR								Town of FREEMAN											
City HUBERTUS						State WI		Zip Code 53033											
County Crawford		Co. Permit #		Notification #		Completed 11-30-2000		Subdivision Name				Lot #							
												Block #							
Well Constructor (Business Name) DONALD C KIRSCHBAUM				Lic. # 170		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.3504 °N -91.05907 °W									
						Well Plan Approval #				Method Code GPS008									
Address 16189 DUTCH HILL RD BOSCOBEL WI 53805-9144						Approval Date (mm-dd-yyyy)				SW SW Section Township Range or Govt Lot # 11 10 N 6 W									
Hicap Permanent Well #		Common Well #		Specific Capacity 2.7						2. Well Type New Well									
										of previous unique well # constructed in									
										Reason for replaced or reconstructed well ?									
										Construction Type Drilled									
3. Well serves 1 # of HOME						Hicap Well ? No													
Private, potable						Hicap Property ? No													
Heat Exchange ___ # of drillholes						Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)				
10 Surface 275											- - C -		CLAY		Surface 18				
6 275 460											- - L -		LIMEROCK		18 140				
			Rotary - Mud Circulation								- - N -		SANDROCK		140 260				
			Yes Rotary - Air No								- - H -		SHALE		260 430				
			Yes Rotary - Air & Foam No								- - N -		SAND ROCK		430 460				
			Drill-Through Casing Hammer																
			Reverse Rotary																
			Cable-tool Bit ___ in. dia...																
			Dual Rotary																
			Yes Temp. Outer Casing 10in. dia																
			Yes Removed? 18depth ft. (If NO explain on back side)																
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		350 ft. below ground surface				12 in. above grade					
6		NEW BLACK STEEL SAWHILL PIPE ASTM-53-B-PE				Surface		275											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes					
										Pumping level 353 ft. below surface				Disinfected ? Yes					
										Pumping at 8 GP M for 2 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?					
Method PRESSURE TREMIE																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?									
CEMENT				Surface		275		110 S											
13. Constructor / Supervisory Driller														Lic #		Date Signed			
DDK																12-01-2000			
Drill Rig Operator														Lic or Reg #		Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 06-25-2001

Updated On: 09-23-2022

Review Status: