Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OJ581

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: COLLIER, DON	Phone #
Mailing Address: 1271 HUBERTS DR	
City: HUBERTUS	State: WI — Zip Code: 53033
County: Crawford	Co. Permit #	Notification #	Completed: 11-30-2000
Well Constructor (Business Name): DONALD C KIRSCHBAUM	Lic #: 170	Facility ID # (Public Wells)
Address: 16189 DUTCH HILL RD BOSCOBEL WI 53805-9144	Well Plan Approval #	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 2.7

1. Well Location

Town of FREEMAN

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.3504 °N -91.05907 °W	GPS008

SW SW or Govt Lot #	Section: 11	Township: 10 N	Range: 6 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	275
6	275	460

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Yes — Rotary - Air & Foam ..... — No
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 18depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	18
-	-	L	-	LIMEROCK	18	140
-	-	N	-	SANDROCK	140	260
-	-	H	-	SHALE	260	430
-	-	N	-	SAND ROCK	430	460

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL SAWHILL PIPE ASTM-53-B-PE	Surface	275
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

350 ft. below ground surface

10. Pump Test

Pumping level 353 ft. below surface

Pumping at 8 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PRESSURE TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	275	110 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DDK		12-01-2000
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 06-25-2001 Updated On: 09-23-2022 Review Status: