

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OJ582		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner LEE, DARREL					Phone #			1. Well Location				Fire # (if avail.)									
Mailing Address E1681 CO RD UU					Town of WHEATLAND							Street Address or Road Name and Number COUNTY UU									
City DE SOTO			State WI		Zip Code 54624																
County Vernon		Co. Permit #		Notification #			Completed 12-12-2000		Subdivision Name			Lot #		Block #							
Well Constructor (Business Name) DONALD C KIRSCHBAUM				Lic. # 170		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code									
Address 16189 DUTCH HILL RD BOSCOBEL WI 53805-9144				Well Plan Approval #			SE SE Section Township Range or Govt Lot # 36 12 N 7 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled												
Approval Date (mm-dd-yyyy)				Specific Capacity 2																	
Hicap Permanent Well #				Common Well #		Hicap Well ? No Hicap Property ? No Hicap Potable ?			Heat Exchange ___ # of drillholes												
3. Well serves 1 # of HOME Private, potable				4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method										8. Geology											
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock							Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)							
10 Surface 273			Rotary - Mud Circulation							- - C - CLAY		Surface 18									
6 273 500			<u>Yes</u> Rotary - Air <u>No</u> <u>Yes</u> Rotary - Air & Foam <u>No</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? 18depth ft. (If NO explain on back side)							- - L - LIMEROCK		18 190									
										- - N - SANDROCK		190 260									
										- - H - SHALE ROCK		260 450									
										- - N - SANDROCK		450 500									
6. Casing, Liner, Screen										9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		400 ft. below ground surface				12 in. above grade							
6		NEW BLACK STEEL SAWHILL PIPE ASTM-53-B-PE				Surface		273		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 404 ft. below surface Pumping at 8 GP M for 3 Hrs. Pumping Method ?				Filled & Sealed Well(s) as needed?							
7. Grout or Other Sealing Material										12. Notified Owner of need to fill & seal ?											
Method PRESSURE TREMIE										13. Constructor / Supervisory Driller											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Lic #				Date Signed							
CEMENT				Surface		273		135 S		DK				12-30-2000							
										Drill Rig Operator				Lic or Reg #				Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Building Overhang		50
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 07-19-2001

Updated On: 07-19-2001

Review Status: