Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OK031

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HANUS, PAUL & HEIDE			Phone #: (920)262-1998
Mailing Address: 119 S WARREN ST			
City: WATERTOWN	State: WI	Zip Code: 53094	
County: Jefferson	Co. Permit #:	Notification #:	Completed: 09-07-2001

Well Constructor (Business Name): ALBIN VOGEL	Lic. #: 634	Facility ID # (Public Wells):	
Address: W4771 HWY 18 JEFFERSON WI 53549-9801		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.4	

1. Well Location

Town of WATERTOWN

Fire # (if avail.):

Street Address or Road Name and Number: N9001 WILLOW RD WATERTOWN WI 5

Subdivision Name	Lot #	Block #
CSM3798	1	

Latitude / Longitude in Decimal Degree (DD)				Method Code
43.1704	°N	-88.8048	°W	GCD013

SE	SW	Section	Township	Range
or Govt Lot #		11	8 N	14 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	21
6	21	217

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 10in. dia... No
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	P	-	HARDPAN	Surface	56
-	-	C	-	CLAY	56	112
-	-	L	-	LIMEROCK	112	127
-	-	N	-	SAND ROCK	127	217

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL PLAIN END WITH WELDED JOINTS WEIGHING 18.97 LBS. PR. FT. ASTM-A53 MADE BY IPSCO U.S.A.	Surface	112
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY & BENTONITE	Surface	21	

9. Static Water Level

75 ft. below ground surface

10. Pump Test

Pumping level 86 ft. below surface

Pumping at 15 GP M for 6 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

NO OTHER WELLS ON PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
AV		09-17-2001
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
AMV		09-17-2001

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		34	Wastewater Sump		47
Building Overhang		5	Sewer - Building Sanitary		48

Comment:

Created On: 10-08-2001 Updated On: 09-26-2019 Review Status: