

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OK031		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner HANUS, PAUL & HEIDE						Phone # (920)262-1998		1. Well Location				Fire # (if avail.)					
Mailing Address 119 S WARREN ST						Town of WATERTOWN						Street Address or Road Name and Number					
City WATERTOWN						State WI		Zip Code 53094				N9001 WILLOW RD WATERTOWN WI 5					
County Jefferson		Co. Permit #		Notification #		Completed 09-07-2001		Subdivision Name CSM3798				Lot # 1		Block #			
Well Constructor (Business Name) ALBIN VOGEL				Lic. # 634		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.1704 °N -88.8048 °W				Method Code GCD013			
Address W4771 HWY 18 JEFFERSON WI 53549-9801				Well Plan Approval #				SE SW		Section 11		Township 8 N		Range 14 E			
				Approval Date (mm-dd-yyyy)				or Govt Lot #									
Hicap Permanent Well #				Common Well #		Specific Capacity 1.4				2. Well Type New Well				of previous unique well #		constructed in	
Reason for replaced or reconstructed well ?				NEW HOME				Construction Type Drilled									
3. Well serves 1 # of Private, potable						Hicap Well ? No											
Heat Exchange ___ # of drillholes						Hicap Property ? No											
Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock														
10 Surface 21			Rotary - Mud Circulation														
6 21 217			Rotary - Air														
			Rotary - Air & Foam														
			Drill-Through Casing Hammer														
			Reverse Rotary														
			Yes Cable-tool Bit 10in. dia... No														
			Dual Rotary														
			Temp. Outer Casing ___ in. dia														
			Removed? ___ depth ft. (If NO explain on back side)														
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
6		NEW STEEL PLAIN END WITH WELDED JOINTS WEIGHING 18.97 LBS. PR. FT. ASTM-A53 MADE BY IPSCO U.S.A.				Surface		112									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material																	
Method																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
CLAY & BENTONITE				Surface		21											
8. Geology																	
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)									
- - P -		HARDPAN				Surface		56									
- - C -		CLAY				56		112									
- - L -		LIMEROCK				112		127									
- - N -		SAND ROCK				127		217									
9. Static Water Level																	
75 ft. below ground surface																	
10. Pump Test																	
Pumping level 86 ft. below surface																	
Pumping at 15 GP M for 6 Hrs.																	
Pumping Method ?																	
11. Well Is																	
14 in. above grade																	
Developed ? Yes																	
Disinfected ? Yes																	
Capped ? Yes																	
12. Notified Owner of need to fill & seal ?																	
Filled & Sealed Well(s) as needed? Yes																	
NO OTHER WELLS ON PROPERTY																	
13. Constructor / Supervisory Driller				Lic #		Date Signed											
AV						09-17-2001											
Drill Rig Operator				Lic or Reg #		Date Signed											
AMV						09-17-2001											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		34	Wastewater Sump		47
Building Overhang		5	Sewer - Building Sanitary		48

Comment:

Created On: 10-08-2001

Updated On: 09-26-2019

Review Status: