Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OK032

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FREEZE, ROBERT & JOANNE			Phone #: (608)423-1360
Mailing Address: 112 1/2 E MAIN ST PO			
City: CAMBRIDGE	State: WI	Zip Code: 53523	
County: Jefferson	Co. Permit #:	Notification #:	Completed: 10-20-2001

Well Constructor (Business Name): ALBIN VOGEL	Lic. #: 634	Facility ID # (Public Wells):	
Address: W4771 HWY 18 JEFFERSON WI 53549-9801		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.1	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of OAKLAND

Fire # (if avail.):

Street Address or Road Name and Number: N3210 CTY HWY A FORT ATKINSON

Subdivision Name: CSM4114-20-113	Lot #: 1	Block #:

Latitude / Longitude in Decimal Degree (DD): 42.9609 °N -88.9633 °W				Method Code: GCD013
SE NW or Govt Lot #	Section: 28	Township: 6 N	Range: 13 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	21
6	21	292

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia... — No
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 21depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	12
-	-	C	S	SANDY CLAY	12	47
-	-	C	-	CLAY	47	126
-	-	P	-	HARDPAN	126	177
-	-	C	-	CLAY	177	222
-	-	L	-	LIMEROCK	222	264
-	-	N	-	SANDROCK	264	292

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL PLAIN END WITH WELDED JOINTS WEIGHING 18.97 LBS. PR. FT. ASTM A-53 MADE BY IPSCO U.S.A.	Surface	222
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY & BENTONITE	Surface	21	

9. Static Water Level
35 ft. below ground surface

10. Pump Test
Pumping level 42 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes
NO OTHER WELLS ON PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
AV		11-19-2001
Drill Rig Operator	Lic or Reg #	Date Signed
MV		11-19-2001

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		76
Building Drain - Sanitary		41
Building Overhang		10
Clearwater Sump		47
Foundation Drain to Clearwater		10
Sewer - Building Sanitary		48
Septic or Holding, or POWTS Tank		57

Comment:

Created On: 12-10-2001 Updated On: 09-26-2019 Review Status: