

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OK033		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner YAMBOR, SCOTT & TAMMY						Phone # (920)563-8285		1. Well Location				Fire # (if avail.)							
Mailing Address 720 COVENTRY CIR						Town of FARMINGTON						Street Address or Road Name and Number N5026 PROBST LN HELENVILLE WI							
City FORT ATKINSON				State WI		Zip Code 53538													
County Jefferson		Co. Permit #		Notification #		Completed 11-10-2001		Subdivision Name CSM 2596-10-2				Lot # 2		Block #					
Well Constructor (Business Name) ALBIN VOGEL				Lic. # 634		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.0258 °N -88.7282 °W				Method Code GCD013					
Address W4771 HWY 18 JEFFERSON WI 53549-9801						Well Plan Approval #				NE SW Section Township Range or Govt Lot # 33 7 N 15 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME Construction Type Drilled							
Approval Date (mm-dd-yyyy)						Hicap Permanent Well # Common Well # Specific Capacity 1.5													
Hicap Permanent Well # Common Well #																			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?				4. Potential Contamination Sources - ON REVERSE SIDE									
5. Drillhole Dimensions and Construction Method						8. Geology													
Dia. (in.)		From (ft.)		To (ft.)						Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)	
10		Surface		21		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- - P - HARD PAN - - P S SANDY HARD PAN - - C S SANDY CLAY - - C - CLAY - - L - LIMEROCK - - N - SAND ROCK				Surface		74			
6		21		345		Yes No				74 147 190 262 327 345				11. Well Is 14 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes					
6. Casing, Liner, Screen						9. Static Water Level				47 ft. below ground surface									
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)								10. Pump Test			
6		NEW STEEL PLAIN END WITH WELDED JOINTS WEIGHING 18.97 LBS. PR. FT. ASTMA-53 MADE BY IPSCO U.S.A.				Surface		262		Pumping level 57 ft. below surface Pumping at 15 GP M for 4 Hrs. Pumping Method ?				12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes NO OTHER WELLS ON PROPERTY					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		13. Constructor / Supervisory Driller								Lic #	
7. Grout or Other Sealing Material						Method				Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement	
CLAY & BENTONITE						Surface				21		AV				12-04-2001			
Drill Rig Operator						Lic or Reg #				Date Signed									
AMV						12-04-2001													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		28

Comment:

Created On: 01-03-2002

Updated On: 09-26-2019

Review Status: