Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OK033

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: YAMBOR, SCOTT & TAMMY			Phone #: (920)563-8285
Mailing Address: 720 COVENTRY CIR			
City: FORT ATKINSON	State: WI	Zip Code: 53538	
County: Jefferson	Co. Permit #:	Notification #:	Completed: 11-10-2001

Well Constructor (Business Name): ALBIN VOGEL	Lic. #: 634	Facility ID # (Public Wells):	
Address: W4771 HWY 18 JEFFERSON WI 53549-9801		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.5	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Fire # (if avail.):

Town of FARMINGTON

Street Address or Road Name and Number: N5026 PROBST LN HELENVILLE WI

Subdivision Name: CSM 2596-10-2	Lot #: 2	Block #:

Latitude / Longitude in Decimal Degree (DD): 43.0258 °N -88.7282 °W			Method Code: GCD013
NE SW or Govt Lot #:	Section: 33	Township: 7 N	Range: 15 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	21
6	21	345

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 10in. dia... No
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	P	-	HARD PAN	Surface	74
-	-	P	S	SANDY HARD PAN	74	147
-	-	C	S	SANDY CLAY	147	190
-	-	C	-	CLAY	190	262
-	-	L	-	LIMEROCK	262	327
-	-	N	-	SAND ROCK	327	345

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL PLAIN END WITH WELDED JOINTS WEIGHING 18.97 LBS. PR. FT. ASTMA-53 MADE BY IPSCO U.S.A.	Surface	262
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY & BENTONITE	Surface	21	

9. Static Water Level
47 ft. below ground surface

10. Pump Test
Pumping level 57 ft. below surface
Pumping at 15 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes
NO OTHER WELLS ON PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
AV		12-04-2001
Drill Rig Operator	Lic or Reg #	Date Signed
AMV		12-04-2001

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		28

Comment:

Created On: 01-03-2002 Updated On: 09-26-2019 Review Status: