

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OK034		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner JOHNSON, DEAN & SANDRA						Phone # (920)568-1820		1. Well Location				Fire # (if avail.)			
Mailing Address 331 GROVE ST						Town of KOSHKONONG						Street Address or Road Name and Number N1768 LENA LN FORT ATKINSON WI			
City FORT ATKINSON			State WI		Zip Code 53538			Subdivision Name 2ND ADDITION TO DELLETTE TERR				Lot # 52		Block #	
County Jefferson		Co. Permit #		Notification #		Completed 11-24-2001		Latitude / Longitude in Decimal Degree (DD) 42.9048 °N -88.8298 °W				Method Code GCD013			
Well Constructor (Business Name) ALBIN VOGEL				Lic. # 634		Facility ID # (Public Wells)		SE SW Section Township Range or Govt Lot # 10 5 N 14 E		2. Well Type New Well			of previous unique well # constructed in		
Address W4771 HWY 18 JEFFERSON WI 53549-9801				Well Plan Approval #		Approval Date (mm-dd-yyyy)		Reason for replaced or reconstructed well ? NEW HOME							
Hicap Permanent Well #			Common Well #		Specific Capacity 1.7		Construction Type Drilled								
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 21			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit 610in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)												
6 21 182															
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.) To (ft.)							
- - C S				SANDY CLAY				Surface		7					
- - C -				CLAY				7		52					
- - L -				LIMEROCK				52		145					
- - N -				SANDROCK				145		182					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)									
6		NEW STEEL PLAIN EDN WITH WELDED JOINTS WEIGHING 18.97 LBS. PR. FT. ASTM A-53 MADE BY IPSCO U.S.A.				Surface		52							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)									
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.) To (ft.)		# Sacks Cement									
CLAY & BENTONITE				Surface		21									
9. Static Water Level															
40 ft. below ground surface															
10. Pump Test															
Pumping level 49 ft. below surface Pumping at 15 GP M for 4 Hrs. Pumping Method ?															
11. Well Is															
14 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes NO OTHER WELLS ON PROPERTY															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
AV										12-04-2001					
Drill Rig Operator								Lic or Reg #		Date Signed					
AMV										12-04-2001					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		67	Clearwater Sump		13
Building Overhang		11	Foundation Drain to Clearwater		12
			Sewer - Building Sanitary		71

Comment:

Created On: 01-03-2002

Updated On: 09-26-2019

Review Status: