Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OK034

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOHNSON, DEAN & SANDRA	Phone #: (920)568-1820
Mailing Address: 331 GROVE ST	
City: FORT ATKINSON	State: WI Zip Code: 53538
County: Jefferson	Co. Permit #:
Notification #:	Completed: 11-24-2001
Well Constructor (Business Name): ALBIN VOGEL	Lic. #: 634
Facility ID # (Public Wells):	
Address: W4771 HWY 18 JEFFERSON WI 53549-9801	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.7	

1. Well Location

Town of KOSHKONONG

Fire # (if avail.):

Street Address or Road Name and Number: N1768 LENA LN FORT ATKINSON WI

Subdivision Name	Lot #	Block #
2ND ADDITION TO DELLETTE TERR	52	

Latitude / Longitude in Decimal Degree (DD): 42.9048 °N -88.8298 °W

Method Code: GCD013

SE SW or Govt Lot #	Section	Township	Range
	10	5 N	14 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	21
6	21	182

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Yes Cable-tool Bit 610in. dia... No

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	S	SANDY CLAY	Surface	7
-	-	C	-	CLAY	7	52
-	-	L	-	LIMEROCK	52	145
-	-	N	-	SANDROCK	145	182

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL PLAIN EDN WITH WELDED JOINTS WEIGHING 18.97 LBS. PR. FT. ASTM A-53 MADE BY IPSCO U.S.A.	Surface	52
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY & BENTONITE	Surface	21	

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 49 ft. below surface

Pumping at 15 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

NO OTHER WELLS ON PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
AV		12-04-2001
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
AMV		12-04-2001

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		67	Clearwater Sump		13
Building Overhang		11	Foundation Drain to Clearwater		12
			Sewer - Building Sanitary		71

Comment:

Created On: 01-03-2002 Updated On: 09-26-2019 Review Status: