Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OM816

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HANSON, ANDY	Phone #: (715)735-3312
Mailing Address: W1061 MADSEN RD	
City: MARINETTE	State: WI — Zip Code: 54143
County: Marinette	Co. Permit #:
Notification #	Completed: 06-17-2003
Well Constructor (Business Name): BRYAN KOZIKOWSKI	Lic. #: 56
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: KOZIKOWSKI WELL & PUMP, MENOMINEE MI 49858	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 1.2	

1. Well Location

Town of PESHTIGO	Fire # (if avail.): W1061
Street Address or Road Name and Number: MADSEN RD	
Subdivision Name	Lot # — Block #
Latitude / Longitude in Decimal Degree (DD): 45.0633 °N -87.6482 °W	Method Code: GCD013
NE NW or Govt Lot #	Section: 24 — Township: 30 N — Range: 23 E

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	88

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	N	S	-	FINE SAND	Surface	28
-	-	L	-	TAN & GRAY MARBLED LIMESTONE	15	88
-	M	Y	-	MED SAND & GRAVEL	28	50
-	-	C	G	CLAY & STONE	50	73

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL 18.97 ASTMA53B WHEATLAND WELDED JOINTS	Surface	73
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

6 ft. below ground surface

10. Pump Test

Pumping level 16 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: MOUNDED WHILE DRIVING

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 BENTONITE	Surface	73	4 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BK		06-20-2003
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		52	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 09-02-2003 Updated On: 10-22-2019 Review Status: