

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OM817		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner SWANSON, MIKE						Phone # (715)732-0973		1. Well Location				Fire # (if avail.)			
Mailing Address N2180 SHORE DR						Town of PESHTIGO						N2180			
City MARINETTE						State WI		Zip Code 54143				Street Address or Road Name and Number SHORE DR			
County Marinette		Co. Permit #		Notification #		Completed 06-17-2003		Subdivision Name			Lot #		Block #		
Well Constructor (Business Name) BRYAN KOZIKOWSKI				Lic. # 56		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.0375 °N -87.6257 °W			Method Code GCD013		
Address KOZIKOWSKI WELL & PUMP MENOMINEE MI 49858				Well Plan Approval #				SW SE		Section 30		Township 30 N		Range 24 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #			Common Well #			Specific Capacity 0.1				2. Well Type Replacement					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No				of previous unique well # constructed in					
						Hicap Property ? No				Reason for replaced or reconstructed well ?					
Heat Exchange ___ # of drillholes						Hicap Potable ?				SLOW POINT					
										Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		634		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)					
T	Q	S	-	TAN SAND CAVING						Surface		10			
K	Q	U	-	BLACK MUCK CAVING						10		26			
T	N	S	-	VERY FINE TAN SAND						26		35			
T	-	C	S	SANDY TAN CLAY						35		132			
-	F	L	-	TAN & GRAY MARBLED LIMESTONE						132		185			
G	-	L	-	GRAY LIMESTONE						185		283			
T	-	L	-	TAN LIMESTONE						283		354			
-	-	L	H	LIMESTONE & SHALE LAYERS						354		412			
		L	N	LIMESTONE & SANDSTONE LAYERS						412		470			
R		H	L	LIMESTONE & RED SHALE LAYERS						470		478			
		L		LIMESTONE						478		616			
R		H		RED SHALE						616		624			
		L	N	LIMESTONE & SANDSTONE						624		634			
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		BLACK STEEL ASTMA53B 18.97 WHEATLAND WELDED JOINTS				Surface		132							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED WHILE DRIVING															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
#8 BENTONITE				Surface		132		4 S							

9. Static Water Level

18 ft. below ground surface

10. Pump Test

Pumping level 180 ft. below surface

Pumping at 10 GP M for 0.5 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

Yes

13. Constructor / Supervisory Driller

Lic #

Date Signed

BK

06-25-2003

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 08-25-2003

Updated On: 10-22-2019

Review Status: