

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OM819		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner BRETL, MIKE						Phone # (715)735-5844		1. Well Location				Fire # (if avail.)			
Mailing Address W1642 RADAR RD						Town of PESHTIGO						W1642			
City MARINETTE						State WI		Zip Code 54143				Street Address or Road Name and Number RADAR RD			
County Marinette		Co. Permit #		Notification #		Completed 06-19-2003		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) BRYAN KOZIKOWSKI				Lic. # 56		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.0581 °N -87.6755 °W				Method Code GCD013	
Address KOZIKOWSKI WELL & PUMP MENOMINEE MI 49858				Well Plan Approval #				SW NW Section Township Range or Govt Lot # 23 30 N 23 E		2. Well Type Replacement					
Hicap Permanent Well #				Common Well #		Specific Capacity				Reason for replaced or reconstructed well ?					
3. Well serves 1 # of						Hicap Well ? No				Construction Type Drilled					
Private, potable						Hicap Property ? No				of previous unique well # constructed in					
Heat Exchange ___ # of drillholes						Hicap Potable ?				Reason for replaced or reconstructed well ?					
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
8.75 Surface 45			Yes Rotary - Mud Circulation No												
6 45 432			Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)												
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology					
6		STEEL 18.97 ASTM A53B WHEATLAND WELDED JOINTS				Surface		45		Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		- - S - SAND Surface 22					
6		STEEL 18.97 ASTM A53B WHEATLAND WELDED JOINTS				Surface		45		- - C G CLAY & STONE 22 45					
6		STEEL 18.97 ASTM A53B WHEATLAND WELDED JOINTS				Surface		45		- - L - TAN & GRAY MARBLED LESTONE 45 89					
6		STEEL 18.97 ASTM A53B WHEATLAND WELDED JOINTS				Surface		45		G - L H GRAY, SHALIE LESTONE 89 129					
6		STEEL 18.97 ASTM A53B WHEATLAND WELDED JOINTS				Surface		45		- - L - TAN & GRAY MARBLED LESTONE 129 238					
6		STEEL 18.97 ASTM A53B WHEATLAND WELDED JOINTS				Surface		45		- - L H LESTONE & SHALE LAYERS 238 285					
6		STEEL 18.97 ASTM A53B WHEATLAND WELDED JOINTS				Surface		45		- - L N LESTONE WITH SANDSTONE & SHALE 285 372					
6		STEEL 18.97 ASTM A53B WHEATLAND WELDED JOINTS				Surface		45		R - H - RED SHALE 372 386					
6		STEEL 18.97 ASTM A53B WHEATLAND WELDED JOINTS				Surface		45		N SANDSTONE 386 391					
6		STEEL 18.97 ASTM A53B WHEATLAND WELDED JOINTS				Surface		45		L H LESTONE & SHALE 391 423					
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
DRILLING MUD & CUTTINGS				Surface		45									

9. Static Water Level

32 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 1 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

Yes

13. Constructor / Supervisory Driller

Lic #

Date Signed

BK

06-19-2003

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Septic or Holding, or POWTS Tank		29

Comment:

Created On: 10-02-2003

Updated On: 10-22-2019

Review Status: