Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OM819

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BRETL, MIKE			Phone #: (715)735-5844
Mailing Address: W1642 RADAR RD			
City: MARINETTE	State: WI	Zip Code: 54143	
County: Marinette	Co. Permit #:	Notification #:	Completed: 06-19-2003

Well Constructor (Business Name): BRYAN KOZIKOWSKI	Lic. #: 56	Facility ID # (Public Wells):	
Address: KOZIKOWSKI WELL & PUMP MENOMINEE MI 49858		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of PESHTIGO

Fire # (if avail.): W1642

Street Address or Road Name and Number: RADAR RD

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 45.0581 °N -87.6755 °W			Method Code: GCD013
SW NW or Govt Lot #	Section: 23	Township: 30 N	Range: 23 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	45
6	45	432

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	22
-	-	C	G	CLAY & STONE	22	45
-	-	L	-	TAN & GRAY MARBLED LIMESTONE	45	89
G	-	L	H	GRAY, SHALIE LIMESTONE	89	129
-	-	L	-	TAN & GRAY MARBLED LIMESTONE	129	238
-	-	L	H	LIMESTONE & SHALE LAYERS	238	285
-	-	L	N	LIMESTONE WITH SANDSTONE & SHALE	285	372
R	-	H	-	RED SHALE	372	386
		N		SANDSTONE	386	391
		L	H	LIMESTONE & SHALE	391	423

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 ASTM A53B WHEATLAND WELDED JOINTS	Surface	45
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD & CUTTINGS	Surface	45	

9. Static Water Level	11. Well Is
32 ft. below ground surface	24 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 80 ft. below surface	Disinfected ? Yes
Pumping at 1 GP M for 1 Hrs.	Capped ? Yes
Pumping Method ?	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BK		06-19-2003
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Septic or Holding, or POWTS Tank		29

Comment:

Created On: 10-02-2003 Updated On: 10-15-2026 Review Status: