

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OM821		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner JANDT, JIM						Phone # (715)789-2264		1. Well Location				Fire # (if avail.)							
Mailing Address N3439 JANDT RD						Town of GROVER						N3439							
City PESHTIGO						State WI		Zip Code 54157				Street Address or Road Name and Number JANDT RD							
County Marinette		Co. Permit #		Notification #		Completed 08-07-2003		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) BRYAN KOZIKOWSKI				Lic. # 56		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.0828 °N -87.8022 °W				Method Code GCD013					
Address KOZIKOWSKI WELL & PUMP MENOMINEE MI 49858				Well Plan Approval #		SW SE		Section 10		Township 30 N		Range 22 E		2. Well Type New Well					
Hicap Permanent Well #				Common Well #		Specific Capacity 3.2				Reason for replaced or reconstructed well ?									
3. Well serves # of PRODUCE WASHING				Hicap Well ? No		Private, potable				Hicap Property ? No		Construction Type Drilled							
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8.75		Surface		40		<u>Yes</u> Rotary - Mud Circulation				<u>No</u>		- - C G		CLAY & STONE		Surface		25	
6		40		250		Rotary - Air						- - L -		TAN & GRAY MARBLED LESTONE		25		60	
						Rotary - Air & Foam						G - L -		GRAY LESTONE		60		65	
						Drill-Through Casing Hammer						- - H -		SHALE		65		74	
						Reverse Rotary						- - L N		LESTONE SANDSTONE & SHALE		74		150	
						Cable-tool Bit ___ in. dia...						G - L -		LT GRAY LESTONE		150		171	
						Dual Rotary						R - H L		RED SHALE & LESTONE		171		184	
						Temp. Outer Casing ___ in. dia						- - N -		SANDSTONE		184		190	
						Removed? ___ depth ft. (If NO explain on back side)						L		LESTONE		190		250	
6. Casing, Liner, Screen																			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)											
6		BLACK STEEL 18.97 ASTM A53B IPSCO WELDED JOINTS				Surface		40											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material																			
Method TREMIE LINE PUMPED																			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement													
CEMENT		Surface		40		8 S													

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 65 ft. below surface

Pumping at 80 GP M for 0.5 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NA

13. Constructor / Supervisory Driller

Lic #

Date Signed

BK

08-09-2003

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Manure Hopper or Reception Tank - Liquid Tight		270	Animal Yard - Include Hutches		125
Building Overhang		7	Barn Gutter		260

Comment:

Created On: 10-02-2003

Updated On: 10-22-2019

Review Status: