Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OM821

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JANDT, JIM	Phone #: (715)789-2264
Mailing Address: N3439 JANDT RD	
City: PESHTIGO	State: WI — Zip Code: 54157
County: Marinette	Co. Permit #: — Notification #: — Completed: 08-07-2003
Well Constructor (Business Name): BRYAN KOZIKOWSKI	Lic. #: 56 — Facility ID # (Public Wells):
Address: KOZIKOWSKI WELL & PUMP, MENOMINEE MI 49858	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 3.2

1. Well Location

Town of GROVER	Fire # (if avail.): N3439
Street Address or Road Name and Number: JANDT RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.0828 °N -87.8022 °W	Method Code: GCD013
SW SE or Govt Lot #:	Section: 10 — Township: 30 N — Range: 22 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves # of PRODUCE WASHING

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	40
6	40	250

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL 18.97 ASTM A53B IPSCO WELDED JOINTS	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE LINE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	40	8 S

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	G	CLAY & STONE	Surface	25
-	-	L	-	TAN & GRAY MARBLED LIMESTONE	25	60
G	-	L	-	GRAY LIMESTONE	60	65
-	-	H	-	SHALE	65	74
-	-	L	N	LIMESTONE SANDSTONE & SHALE	74	150
G	-	L	-	LT GRAY LIMESTONE	150	171
R	-	H	L	RED SHALE & LIMESTONE	171	184
-	-	N	-	SANDSTONE	184	190
		L		LIMESTONE	190	250

9. Static Water Level	11. Well Is
40 ft. below ground surface	24 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 65 ft. below surface	Disinfected ? Yes
Pumping at 80 GP M for 0.5 Hrs.	Capped ? Yes
Pumping Method ?	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
BK		08-09-2003
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Manure Hopper or Reception Tank - Liquid Tight		270	Animal Yard - Include Hutches		125
Building Overhang		7	Barn Gutter		260

Comment:

Created On: 10-02-2003 Updated On: 10-22-2019 Review Status: