

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OM949		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner KNUDSON, MARLA						Phone # (608)583-2778		1. Well Location				Fire # (if avail.)		
Mailing Address 32818 US HWY 14						Town of BUENA VISTA						Street Address or Road Name and Number 33115 MARY ST		
City LONE ROCK				State WI		Zip Code 53556								
County Richland		Co. Permit #		Notification #		Completed 07-08-2003		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) DONALD HERBECK				Lic. # 229		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code			
Address A-D WELL & PUMP SERVICE SEXTONVILLE WI 53584				Well Plan Approval #		NE NE		Section 31		Township 9 N		Range 2 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #		2. Well Type New Well		of previous unique well # constructed in				
Hicap Permanent Well #		Common Well #		Specific Capacity 4		Reason for replaced or reconstructed well ?								
3. Well serves 1 # of				Hicap Well ? No		Construction Type Driven Point								
Private, potable				Hicap Property ? No										
Heat Exchange ____ # of drillholes				Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
2		Surface		45		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
- - Y -				SAND & GRAVEL				Surface		23				
- - P -				HARDPAN				23		27				
- - S -				SAND				27		45				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
2		ASTMA53A SCH 40 L21 T&C RN CBW WHEATLAND				Surface		41						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
2		ALLOY MACHINE STAINLESS STEEL WEDGE 10 SLOT				41		45						
7. Grout or Other Sealing Material														
Method														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
				Surface										
9. Static Water Level														
16 ft. below ground surface														
10. Pump Test														
Pumping level 18 ft. below surface														
Pumping at 8 GP M for 1 Hrs.														
Pumping Method ?														
11. Well Is														
12 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed?														
NONE														
13. Constructor / Supervisory Driller														
DAH														
07-08-2003														
Drill Rig Operator														
Lic or Reg #														
Date Signed														

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Landfill		1500	POWTS dispersal component (soil absorption unit or mound)	>	50
Septic or Holding, or POWTS Tank	>	25	Sewer - Building Sanitary	>	8

Comment:

Created On: 08-01-2003

Updated On: 08-21-2003

Review Status: