Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ON079

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HARTWIG, DONALD			Phone #: (715)831-1521
Mailing Address: 3653 26TH ST			
City: CHIPPEWA FALLS	State: WI	Zip Code: 54729	
County: Chippewa	Co. Permit #: 19035	Notification #	Completed: 03-06-2001

Well Constructor (Business Name): OLSON BROS WELL DRILLING CO INC	Lic. #: 146	Facility ID # (Public Wells)	
Address: 4625 OLSON DR EAU CLAIRE WI 54703-9714		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.7	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of WHEATON

Fire # (if avail.)

Street Address or Road Name and Number
FIRE 3653

Subdivision Name	Lot #	Block #
	4	

Latitude / Longitude in Decimal Degree (DD) °N °W
Method Code

NW NE or Govt Lot #	Section	Township	Range
	20	28 N	10 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	80

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
- Q Y -	SAND, GRAVEL CAVING	Surface	80

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53B USA SAWHILL P.E. STEEL CASING 18.97 FT WELDED JOINTS	Surface	77
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	TEL S. STEEL 015 SLOT SCREEN	77	80

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
53 ft. below ground surface

10. Pump Test
Pumping level 68 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
PO		03-23-2001
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Sewer - Building Sanitary	>	40
Building Overhang	>	10	Septic or Holding, or POWTS Tank	>	80

Comment:

Created On: 06-26-2001 Updated On: 06-26-2001 Review Status: