Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ON080

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DAHL, MOLLY			Phone #: (715)658-1757
Mailing Address: N13321 CTY RD M			
City: NEW AUBURN	State: WI	Zip Code: 54757	
County: Dunn	Co. Permit #:	Notification #:	Completed: 02-11-2001

1. Well Location

Town of SAND CREEK

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): OLSON BROS WELL DRILLING CO INC	Lic. #: 146	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code:
Address: 4625 OLSON DR, EAU CLAIRE WI 54703-9714		Well Plan Approval #:	SW SW or Govt Lot #:	Section: 13
		Approval Date (mm-dd-yyyy):	Township: 31 N	Range: 11 W

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME	Hicap Well ? No	
Private,potable	Hicap Property ? No	
Heat Exchange____# of drillholes	Hicap Potable ?	

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	10
6	10	95

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	Q	Y	-	SAND, GRAVEL, CAVING	Surface	18
-	Q	Y	M	SAND, GRAVEL, SILTY CAVING	18	80
E	-	C	-	GREEN CLAY	80	81
T	-	N	-	BRN SANDSTONE	81	95

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53 USA SAWHILL .280 WELL 18.97 FT P.E. WELDED JOINTS	Surface	83
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 27 ft. below surface

Pumping at 10 GP M for 0.5 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE CHIPS H20 ADDED	Surface	10	4 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

OWNER WILL

13. Constructor / Supervisory Driller	Lic #	Date Signed
PO		02-19-2001
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		6	Sewer - Building Sanitary		25

Comment:

Created On: 06-29-2001 Updated On: 06-29-2001 Review Status: