Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OP230

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: KALLAS, ROBIN		Phone #: (920)582-9733
Mailing Address: W142 WELSCH RD		
City: WINNECONNE	State: WI	Zip Code: 54986
County: Waushara	Co. Permit #:	Notification #: / Completed: 09-18-2001

Well Constructor (Business Name): BUTCH GIBOUR	Lic. #: 17	Facility ID # (Public Wells):	
Address: 7482 CIRCLE DR, LANNON WI 53046		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.7	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of POYSIPPI

Fire # (if avail.): W142

Street Address or Road Name and Number: W142 WELSCH RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.1102 °N -88.88806 °W	GPS008

NE NE or Govt Lot #	Section	Township	Range
	24	19 N	13 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NOT ENOUGH WATER

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	68
6	68	105

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOP SOIL	Surface	1
-	-	S	-	SAND	1	4
-	-	P	G	HARDPAN & STONES	4	51
-	Q	N	-	CAVING SANDSTONE	51	65
-	H	N	-	HARD SANDSTONE	65	105

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. NEW STEEL DRILLER'S PIPE #18.97 ASTM A-53 IPSCO TUBULAR	Surface	68
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD & CUTTINGS	Surface	68	

9. Static Water Level
0 ft. below ground surface

10. Pump Test
Pumping level 14 ft. below surface
Pumping at 24 GP M for 2.5 Hrs.
Pumping Method ?

11. Well Is
22 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
		10-09-2001
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MAS		10-09-2001

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		25	Collector Sewer - San or Storm		147
			Sewer - Building Sanitary		74

Comment:

Created On: 11-16-2001 Updated On: 08-25-2022 Review Status: