Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OR012

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: SEEFELDT, RYAN	Phone #: (715)449-2664
Mailing Address: N451 CTY RD HH	
City: ANIWA	State: WI — Zip Code: 54408
County: Langlade	Co. Permit #:
Notification #	Completed: 02-08-2001
Well Constructor (Business Name): PHILIP J KOEPPEL	Lic. #: 667
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: W8060 S PARK RD, ANTIGO WI 54409-8963	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 9	

1. Well Location
Town of ROLLING
Fire # (if avail.)
Street Address or Road Name and Number
Subdivision Name | Lot # | Block #
Latitude / Longitude in Decimal Degree (DD) °N °W
Method Code
NW SW or Govt Lot # | Section: 28 | Township: 30 N | Range: 11 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	78

Upper Enlarged Drillhole / Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	V	Z	-	NONCAVING GRAVEL & CLAY	Surface	12
-	Q	Z	G	CAVING GRAVEL CLAY BOULDERS	12	50
-	Q	Z	-	GRAVEL WITH CLAY CAVING	50	58
-	-	Y	U	MUDDY GRAVEL & SAND	58	70
-	C	Y	-	CLEAN SAND WITH GRAVEL	70	78

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	BLACK STEEL A53B 14.62#/FT. .258IN WELDED IPSCO	Surface	74
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	S.S. JOHNSON TELESCOPE .012	74	78

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level
58 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 18 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
30 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
PK		02-08-2001
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
SDD		02-08-2001

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 06-06-2001 Updated On: 06-11-2001 Review Status: