

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OS459		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner VANDEHEI, MIKE						Phone # (920)863-6457		1. Well Location				Fire # (if avail.)			
Mailing Address J993 HUMBOLDT RD						Town of HUMBOLDT									
City GREEN BAY						State WI		Zip Code 54311				Street Address or Road Name and Number 4993 HUMBOLDT RD GREEN BAY			
County Brown		Co. Permit #		Notification #		Completed 01-30-2003		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) ERVIN J HEIM				Lic. # 551		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.5024 °N -87.8316 °W				Method Code GCD013	
Address 4904 CHURCH RD RT 2 NEW FRANKEN WI 54229				Well Plan Approval #				SE SE		Section 33		Township 24 N		Range 22 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5				2. Well Type New Well							
3. Well serves # of 1 POND Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
						Hicap Property ? No									
						Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 20			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)												
6 20 70															
			Yes No												
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology					
6		T&C COPPERWELD LTV ASTM-A53-B 19.45#				Surface		55							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)	
										- V C -		CLAY NONCAVING		Surface 37	
										- - P -		HARDPAN		37 55	
										- - L -		LIMESTONE		55 70	
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		9. Static Water Level 13 ft. below ground surface					
DRILL SLURRY				Surface		55									
10. Pump Test Pumping level 55 ft. below surface Pumping at 20 GP for 0.5 Hrs. Pumping Method ?															
11. Well Is 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
EJH										Lic #		Date Signed 01-30-2003			
Drill Rig Operator										Lic or Reg #		Date Signed 01-30-2003			
KEH															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Shoreline/Pool		26	Ditch or Culvert		55

Comment:

Created On: 03-05-2003

Updated On: 11-21-2019

Review Status: