Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OS459

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: VANDEHEI, MIKE	Phone #: (920)863-6457
Mailing Address: J993 HUMBODLT RD	
City: GREEN BAY	State: WI — Zip Code: 54311
County: Brown	Co. Permit #: — Notification #: — Completed: 01-30-2003
Well Constructor (Business Name): ERVIN J HEIM	Lic. #: 551 — Facility ID # (Public Wells):
Address: 4904 CHURCH RD RT 2 NEW FRANKEN WI 54229	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.5

1. Well Location

Town of HUMBOLDT

Fire # (if avail.):

Street Address or Road Name and Number: 4993 HUMBOLDT RD GREEN BAY

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 44.5024 °N -87.8316 °W — Method Code: GCD013

SE	SE	Section	Township	Range
or Govt Lot #		33	24 N	22 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves # of 1 POND

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	70

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	V	C	-	CLAY NONCAVING	Surface	37
-	-	P	-	HARDPAN	37	55
-	-	L	-	LIMESTONE	55	70

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	T&C COPPERWELD LTV ASTM-A53-B 19.45#	Surface	55
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY	Surface	55	

9. Static Water Level

13 ft. below ground surface

10. Pump Test

Pumping level 55 ft. below surface

Pumping at 20 GP for 0.5 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
EJH		01-30-2003
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KEH		01-30-2003

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Shoreline/Pool		26	Ditch or Culvert		55

Comment:

Created On: 03-05-2003 Updated On: 11-21-2019 Review Status: