

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OT937		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner MARKEE, GARY						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address S1046 ST HWY 131						Town of WHITESTOWN						S1046							
City ONTARIO						State WI		Zip Code 54651				Street Address or Road Name and Number STATE HWY 131							
County Vernon		Co. Permit #		Notification #		Completed 10-11-2001		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) AAA QUALITY WELL DRLG INC				Lic. # 6723		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address S2669 CTH HWY V HILLSBORO WI 54634				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 15 14 N 2 W		2. Well Type Replacement				of previous unique well # constructed in							
Hicap Permanent Well #				Common Well #		Specific Capacity 0.2		Reason for replaced or reconstructed well ? STATE MOVING HWY/SOLD PRO				Construction Type Drilled							
3. Well serves 2 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8.75		Surface		105		Rotary - Mud Circulation				- V C -		CLAY NONCAVING		Surface		10			
6		105		180		<u>Yes</u> Rotary - Air <u>No</u> <u>Yes</u> Rotary - Air & Foam <u>No</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? 4depth ft. (If NO explain on back side)				T - H -		SHALE BROWN		10		60			
										T - N -		SANDSTONE BROWN		60		100			
										I - N -		SANDSTONE WHITE		100		180			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		108 ft. below ground surface				18 in. above grade					
6		NEW PLAIN END IPSCO A5OB GR STEEL CASING 18.97#/FT 1280 WELL THICKNESS BUTT TO BUTT WELD W/DRIVE SHOE				Surface		105		10. Pump Test Pumping level 160 ft. below surface Pumping at 12 GP M for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material Method 1IN OUTSIDE TREMMIE												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
NEAT CEMENT PRESSURE GROUTED				Surface		105		50 S		GNP						10-26-2001			
										Drill Rig Operator				Lic or Reg #		Date Signed			
										DS						10-20-2001			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		50

Comment:

Created On: 11-19-2001

Updated On: 11-19-2001

Review Status: