

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OT938		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner SHORT, DELBERT						Phone # (608)337-4509		1. Well Location				Fire # (if avail.)					
Mailing Address E11502 NORWEGIAN VLY						Town of CLINTON						E1150					
City ONTARIO						State WI		Zip Code 54651				Street Address or Road Name and Number NORWEGIAN VALLEY RD					
County Vernon		Co. Permit #		Notification #		Completed 10-13-2001		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) AAA QUALITY WELL DRLG INC				Lic. # 6723		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.7189 °N -90.6804 °W				Method Code GCD013					
Address S2669 CTH HWY V HILLSBORO WI 54634				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 1 14 N 3 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8.75		Surface		84		Rotary - Mud Circulation				- V C -		CLAY NONCAVING		Surface		6	
6		84		180		<u>Yes</u> Rotary - Air <u>No</u> <u>Yes</u> Rotary - Air & Foam <u>No</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? 4depth ft. (If NO explain on back side)				T - H -		SHALE BROWN		6		100	
										T - N -		SANDSTONE L BROWN		100		140	
										I - N -		SANDSTONE WHITE		140		180	
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 120 ft. below ground surface				11. Well Is 12 in. above grade			
6		NEW PLAIN END IPSCO A5OB GR STEEL CASING 18.97#/FT 1280 WELL THICKNESS BUTT TO BUTT WELD W/DRIVE SHOE				Surface		84		10. Pump Test Pumping level 160 ft. below surface Pumping at 12 GP M for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
7. Grout or Other Sealing Material Method 1IN OUTSIDE TREMMIE																	
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
NEAT CEMENT PRESSURE GROUTED		Surface		84		36 S											
13. Constructor / Supervisory Driller												Lic #		Date Signed			
GNP														10-26-2001			
Drill Rig Operator												Lic or Reg #		Date Signed			
DS														10-20-2001			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		5	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 11-19-2001

Updated On: 04-29-2020

Review Status: