Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OT940

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CHAPMAN, DEAN	Phone #: (608)464-3324
Mailing Address: S2472 HENDERSON RD	
City: WONEWOC	State: WI — Zip Code: 53968
County: Sauk	Co. Permit #:
Notification #	Completed: 10-12-2001
Well Constructor (Business Name): AAA QUALITY WELL DRLG INC	Lic. #: 6723
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: S2669 CTH HWY V HILLSBORO WI 54634	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 0.4	

1. Well Location

Town of WOODLAND	Fire # (if avail.): S2498
Street Address or Road Name and Number: HENDERSON RD	
Subdivision Name	Lot # — Block #
Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code

NW	SW	Section	Township	Range
or Govt Lot #		32	13 N	2 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	84
6	84	120

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Yes — Rotary - Air & Foam ..... — No
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 4depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	V	C	-	CLAY (NON CAVING)	Surface	8
T	-	N	-	SANDSTONE (BROWN)	8	12
-	-	L	-	LIMESTONE	12	42
T	-	N	-	SANDSTONE (LT BROWN)	42	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW PE IPSCO A53B STEEL 18.97#/FT .280 WALL BUTT TO BUTT WELD W/ DRIVE SHOE	Surface	84
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method 1 IN OUTSIDE TREMMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT PRESSURE GROUTED	Surface	84	35 S

9. Static Water Level

70 ft. below ground surface

10. Pump Test

Pumping level 100 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GNP		10-26-2001
Drill Rig Operator	Lic or Reg #	Date Signed
CX		10-20-2001

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Building Overhang		10
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 01-31-2002 Updated On: 05-10-2002 Review Status: