Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OT975

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHUH, STEVE			Phone #: (262)790-1174
Mailing Address: 18755 BROOKRIDGE DR			
City: BROOKFIELD	State: WI	Zip Code: 53045	
County: Fond du Lac	Co. Permit #:	Notification #:	Completed: 03-23-2001

Well Constructor (Business Name): DENNIS R LEFEBER	Lic. #: 434	Facility ID # (Public Wells):	
Address: W2593 CNTY Q MALONE WI 53049-1242		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.7	

1. Well Location

Fire # (if avail.): W1059					
Town of MARSHFIELD					
Street Address or Road Name and Number: SOUTHWEST CIRCLE DR					
Subdivision Name:	Lot #:	Block #:			
Latitude / Longitude in Decimal Degree (DD): 43.8633 °N -88.2101 °W					Method Code: GCD013
SW SE or Govt Lot #:	Section: 10	Township: 16 N	Range: 19 E		

2. Well Type Replacement

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: NON COMPLYING

Construction Type: Drilled

3. Well serves 3 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	48

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOPSOIL	Surface	2
-	-	Y	-	SAND & GRAVEL	2	16
-	-	S	-	SAND	16	30
-	-	P	-	HARDPAN	30	44
-	-	G	-	GRAVEL	44	48

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL ASTM A53 W/WELDED JOINTS	Surface	48
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 12 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DRL		04-09-2001
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
BS		03-26-2001

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		64
Building Overhang		4
Downspout/Yard Hydrant		13
Shoreline/Pool		32
Septic or Holding, or POWTS Tank		58

Comment:

Created On: 08-22-2001 Updated On: 10-08-2019 Review Status: