Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OV065

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BROWN, DAN			Phone #: (920)855-2549
Mailing Address: 6083 QUARTERLINE RD			
City: GILLETT	State: WI	Zip Code: 54124	
County: Oconto	Co. Permit #:	Notification #:	Completed: 12-10-2001

Well Constructor (Business Name): BERNARD YOUNG	Lic. #: 696	Facility ID # (Public Wells):	
Address: 10358 HWY 22E GILLETT WI 54124		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

1. Well Location

Town of GILLETT

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
SE SW or Govt Lot #:	Section: 14	Township: 28 N	Range: 18 E

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	135
6	135	163

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	28
-	-	C	-	CLAY	28	135
-	-	L	-	LIMEROCK	135	151
-	-	N	-	SANDSTONE	151	163

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL STEEL 1780 PSI ASTM A-53 WELDED 18.97	Surface	135
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

17 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 30 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD/CUTTINGS	Surface	135	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed
BY		12-10-2001

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		20

Comment:

Created On: 01-31-2002 Updated On: 01-31-2002 Review Status: