Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OV079

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MONTIE, MIKE			Phone #: (920)829-5980
Mailing Address: 8151 CTY K			
City: OCONTO FALLS	State: WI	Zip Code: 54124	
County: Oconto	Co. Permit #:	Notification #:	Completed: 08-12-2002

Well Constructor (Business Name): BERNARD YOUNG	Lic. #: 696	Facility ID # (Public Wells):	
Address: 10358 HWY 22E GILLETT WI 54124		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.6	

1. Well Location

Town of SPRUCE					Fire # (if avail.): 8151
Street Address or Road Name and Number: CTY K					
Subdivision Name			Lot #		Block #
Latitude / Longitude in Decimal Degree (DD): 44.97 °N -88.2159 °W					Method Code: GCD013
NE	NW	Section: 20	Township: 29 N		Range: 19 E
or Govt Lot #					

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?: HOME
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	42
6	42	45

Upper Enlarged Drillhole: Yes
Lower Open Bedrock: No
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	28
-	-	C	-	CLAY	28	37
-	-	S	-	SAND	37	45

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STAINLESS STEEL 1780 PST ASTM A-53 WELDED 18.97	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	SCREEN-KPACKER 15 SLOT	42	45

9. Static Water Level
8 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD/CUTTING	Surface	42	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed
BY		08-12-2002

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 10-28-2002 Updated On: 11-15-2019 Review Status: