

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OV079		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner MONTIE, MIKE						Phone # (920)829-5980		1. Well Location				Fire # (if avail.) 8151									
Mailing Address 8151 CTY K						Town of SPRUCE						8151									
City OCONTO FALLS						State WI		Zip Code 54124				Street Address or Road Name and Number CTY K									
County Oconto		Co. Permit #		Notification #		Completed 08-12-2002		Subdivision Name				Lot # Block #									
Well Constructor (Business Name) BERNARD YOUNG				Lic. # 696		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.97 °N -88.2159 °W				Method Code GCD013							
Address 10358 HWY 22E GILLETT WI 54124				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 20 29 N 19 E		2. Well Type New Well				of previous unique well # constructed in									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6		Reason for replaced or reconstructed well ? HOME				Construction Type Drilled											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		4. Potential Contamination Sources - ON REVERSE SIDE				5. Drillhole Dimensions and Construction Method									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock											
8.75		Surface		42		Yes Rotary - Mud Circulation				No											
6		42		45		Rotary - Air				Rotary - Air & Foam											
Drill-Through Casing Hammer		Reverse Rotary		Cable-tool Bit ___ in. dia...		Dual Rotary				Temp. Outer Casing ___ in. dia											
Removed? ___ depth ft. (If NO explain on back side)		6		STAINLESS STEEL 1780 PST ASTM A-53 WELDED 18.97		Surface		42		8. Geology											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
6		SCREEN-KPACKER 15 SLOT				42		45		- - S -		SAND		Surface		28					
6		SCREEN-KPACKER 15 SLOT				42		45		- - C -		CLAY		28		37					
6		SCREEN-KPACKER 15 SLOT				42		45		- - S -		SAND		37		45					
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is											
Dia. (in.) Material, Weight, Specification Manufacturer & Method of Assembly						From (ft.)		To (ft.)		8 ft. below ground surface				12 in. above grade							
6 STAINLESS STEEL 1780 PST ASTM A-53 WELDED 18.97						Surface		42		10. Pump Test				Developed ? Yes							
Dia. (in.) Screen type, material & slot size						From (ft.)		To (ft.)		Pumping level 25 ft. below surface				Disinfected ? Yes							
6 SCREEN-KPACKER 15 SLOT						42		45		Pumping at 10 GP M for 2 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?				Filled & Sealed Well(s) as needed? Yes											
Method						Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller		Lic #		Date Signed	
DRILLING MUD/CUTTING						Surface		42		DRILL RIG OPERATOR				Lic or Reg #		Date Signed					
DRILLING MUD/CUTTING						Surface		42		BY				08-12-2002		08-12-2002					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 10-28-2002

Updated On: 11-15-2019

Review Status: