Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OV273

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROSSIO, HENERY			Phone #
Mailing Address: 16481 BOYLAN RD			
City: STONE LAKE	State: WI	Zip Code: 54868	
County: Sawyer	Co. Permit #	Notification #	Completed: 12-10-2001

Well Constructor (Business Name): FROEMEL WELL & PUMP REPAIR INC	Lic. #: 6080	Facility ID # (Public Wells)	
Address: 15251 W COUNTY B HAYWARD WI 54843-4100		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1.7	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of SAND LAKE

Fire # (if avail.): 16481

Street Address or Road Name and Number: BOYLAN RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.8697 °N	-91.5214 °W			GCD013
NW or Govt Lot #	NW	Section: 17	Township: 39 N	Range: 9 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
PUMP STUCK IN OLD WELL

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	91

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 4in. dia... No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND & GRAVEL	Surface	60
-	-	Y	C	SAND GRAVEL CLA	60	70
-	-	C	-	CLAY	70	85
-	-	Y	-	SAND & GRAVEL	85	91

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	IPSCO NEW WELDED ASTM A53-B 10.79#/FT	Surface	88
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	SS 15 SLOT	88	91

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
50 ft. below ground surface

10. Pump Test
Pumping level 57 ft. below surface
Pumping at 12 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
21 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes
OWNER

13. Constructor / Supervisory Driller	Lic #	Date Signed
GO		12-10-2001
Drill Rig Operator	Lic or Reg #	Date Signed
DF		12-10-2001

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70

Type	Qualifier	Distance
Building Overhang		12
Septic or Holding, or POWTS Tank		60

Comment:

Created On: 01-31-2002 Updated On: 06-24-2020 Review Status: