Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OV275

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ZASTOUPIL, LEONARD	Phone #
Mailing Address: 9930 N STATE RD 27	
City: HAYWARD	State: WI — Zip Code: 54843
County: Sawyer	Co. Permit #	Notification #	Completed: 12-14-2001
Well Constructor (Business Name): FROEMEL WELL & PUMP REPAIR INC	Lic. #: 6080
Address: 15251 W COUNTY B HAYWARD WI 54843-4100	
Hicap Permanent Well #	Common Well #

Facility ID # (Public Wells)

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Specific Capacity: 2

1. Well Location

Fire # (if avail.): 9930

Town of HAYWARD

Street Address or Road Name and Number: STATE RD 27

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD) °N °W

Method Code

SW NE or Govt Lot # | Section: 33 | Township: 41 N | Range: 9 W

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: OLD WELL FAILED

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	31

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 4in. dia... No
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND & GRAVEL	Surface	31

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK STEEL WELDED 10.79#/FT ASTM A53-B IPSCO	Surface	28
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	SS 20 SLOT	28	31

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

18 ft. below ground surface

10. Pump Test

Pumping level 23 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

22 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
GO		12-14-2001
Drill Rig Operator	Lic or Reg #	Date Signed
DF		12-14-2001

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		180
			Septic or Holding, or POWTS Tank		180

Comment:

Created On: 01-31-2002 Updated On: 01-31-2002 Review Status: