

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OV276		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner LOOMIS, ROD						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 39776 N BECK RD								Town of SAND LAKE				16055	
City LAKE VILLA						State IL		Zip Code 60046				Street Address or Road Name and Number 16055W STATE HWY 27/70	
County Sawyer		Co. Permit #		Notification #		Completed 12-18-2001		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) FROEMEL WELL & PUMP REPAIR INC				Lic. # 6080		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.8615 °N -91.5002 °W				Method Code GCD013	
Address 15251 W COUNTY B HAYWARD WI 54843-4100				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 16 39 N 9 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
4		Surface		140		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 4in. dia... <u>No</u> Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes - J S - RED & BROWN SAND FE WATER - - Y M SILT SAND & GRAVEL T - S M SILT SAND BROWN CLAY R - X G RED CLAY SAND GRAVEL - A G N COARSE GRAVEL SAND ROCKS			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
4		IPSCO NEW BLACK STEEL WELDED ASTM A53-B 10.79#/FT				Surface		137		14 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
4		15 SLOT SS				137		140		18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ?			
				Surface						Filled & Sealed Well(s) as needed? No NEW HOUSE			
13. Constructor / Supervisory Driller								Lic #		Date Signed			
GO										12-18-2001			
Drill Rig Operator								Lic or Reg #		Date Signed			
DF										12-18-2001			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		20	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 01-31-2002

Updated On: 06-24-2020

Review Status: