Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QI362

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MEYERS, MIKE			Phone #
Mailing Address: W154 N9985 MOONLITE			
City: GERMANTOWN	State: WI	Zip Code: 53022	
County: Washington	Co. Permit #	Notification #	Completed: 12-19-2001

Well Constructor (Business Name): ANHALT WELL & PUMP	Lic. #: 6726	Facility ID # (Public Wells)	
Address: 7318 IRELAND DR HARTFORD WI 53027		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.4	

1. Well Location

Village of SLINGER

Fire # (if avail.)

Street Address or Road Name and Number: 621 BAY BERRY LN

Subdivision Name: MEADOWWOOD	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 43.3521 °N -88.2908 °W				Method Code: GCD013
NE NW or Govt Lot #	Section: 7	Township: 10 N	Range: 19 E	

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

NEW HOME

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	135

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	4
-	-	Y	-	SAND & GRAVEL	4	13
-	-	S	-	SAND	13	39
-	-	G	C	GRAVEL/CLAY	39	47
-	-	C	-	CLAY	47	65
-	-	G	C	GRAVEL/CLAY	65	101
-	-	L	-	LIMESTONE	101	135

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53-B P/E SAWHILL 18.97 LB/FT NEW, WELDED	Surface	101
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CRUMBLES	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NO WELLS

13. Constructor / Supervisory Driller	Lic #	Date Signed
AA		12-31-2001
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
AA		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	150	Foundation Drain to Clearwater		15
Building Overhang		14	Sewer - Building Sanitary		65
Clearwater Sump		17	Septic or Holding, or POWTS Tank	>	100

Comment:

Created On: 01-28-2002 Updated On: 07-05-2019 Review Status: