

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QI364		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner GRAYSZKIEWICZ, KAREN						Phone # (262)820-3325		1. Well Location				Fire # (if avail.)			
Mailing Address N74 W22317 ALTA VIST						Town of LISBON									
City SUSSEX						State WI		Zip Code 53089							
County Waukesha		Co. Permit #		Notification #		Completed 01-28-2002		Subdivision Name MT SHADOW ADD #2				Lot # 9 Block # 3			
Well Constructor (Business Name) ANHALT WELL & PUMP				Lic. # 6726		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.1259 °N -88.2701 °W				Method Code GCD013			
Address 7318 IRELAND DR HARTFORD WI 53027				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW SE		Section 29		Township 8 N		Range 19 E	
								or Govt Lot #							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6		2. Well Type New Well									
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ? NEW HOME							
						Hicap Property ? No									
						Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) 6		From (ft.) Surface		To (ft.) 263		Upper Enlarged Drillhole				Lower Open Bedrock					
				Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)	
						- - C G		CLAY & STONES				Surface		9	
						- - G -		GRAVEL				9		17	
						- - P -		HARDPAN				17		53	
						- - G -		GRAVEL				53		68	
						R - C -		RED CLAY				68		80	
						- - P -		HARDPAN				80		144	
						- - L -		LIMESTONE				144		263	
6. Casing, Liner, Screen															
Dia. (in.) 6		Material, Weight, Specification SAWHILL ASTM A53-B P/E 18.97 LB/FT WELDED, NEW				From (ft.) Surface		To (ft.) 144		9. Static Water Level 165 ft. below ground surface					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is 18 in. above grade					
										Developed ? Yes Disinfected ? Yes Capped ? Yes					
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material CRUMBLES		From (ft.) Surface		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NO WELLS							
13. Constructor / Supervisory Driller															
TA		Lic #		Date Signed											
Drill Rig Operator		Lic or Reg #		Date Signed											
TA															

4a. Potential Contamination Sources

Is the well located in floodplain ?

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Foundation Drain to Clearwater		15
Building Overhang		12	Sewer - Building Sanitary		40
Clearwater Sump		60	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 03-14-2002

Updated On: 07-11-2019

Review Status: