Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QJ209

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HEIL, RON			Phone #: (715)325-5773
Mailing Address: 8474 BERACHAH TRL			
City: NEKOOSA	State: WI	Zip Code: 54457	
County: Wood	Co. Permit #:	Notification #:	Completed: 08-29-2002

1. Well Location

Town of SARATOGA

Fire # (if avail.)

Street Address or Road Name and Number: 8474 BERACHAH TRL

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ROTH PLUMBING & WELL DRILLING	5857	

Latitude / Longitude in Decimal Degree (DD): 44.3177 °N -89.8464 °W

Method Code: GCD013

Well Plan Approval #:

SE	NE	Section	Township	Range
or Govt Lot #		12	21 N	5 E

Address: 618 HWY 73 S
NEKOOSA WI 54457

Approval Date (mm-dd-yyyy):

2. Well Type Replacement

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		6.3

Reason for replaced or reconstructed well ?: OLD WELL FAILING

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	51.7

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	21
-	-	C	-	CLAY	21	28
-	-	S	-	SAND	28	45
-	A	Y	-	CRS SAND & GRAVEL	45	51.7

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	SAWHILL ASTM A53B 6.625 X .280 EL 21 HT A13786 2/02 WELDED	Surface	48.7
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON SS 12 SLOT	48.7	51.7

9. Static Water Level

34.6 ft. below ground surface

10. Pump Test

Pumping level 37 ft. below surface

Pumping at 15 GP for 2 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR		09-04-2002
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		73	Sewer - Building Sanitary		35
Building Drain - Sanitary		31	Fuel Oil Tank		27
Building Overhang		7	Septic or Holding, or POWTS Tank		65

Comment:

Created On: 10-02-2002 Updated On: 05-05-2020 Review Status: