

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QJ211		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner BRAAKSMA, RANDALL						Phone # (715)424-5353		1. Well Location				Fire # (if avail.)		
Mailing Address 3820 HERITAGE RIDGE DR						Town of GRAND RAPIDS								
City WISCONSIN RAPIDS						State WI		Zip Code 54494				Street Address or Road Name and Number 3820 HERITAGE RIDGE DR		
County		Co. Permit #		Notification #		Completed 09-01-2002		Subdivision Name HERITAGE RIDGE			Lot # 5		Block #	
Well Constructor (Business Name) ROTH PLUMBING & WELL DRILLING				Lic. # 5857		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.3598 °N -89.7529 °W			Method Code GCD013			
Address 618 HWY 73 S NEKOOSA WI 54457				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SW NE Section Township Range or Govt Lot # 26 22 N 6 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled				
Hicap Permanent Well #		Common Well #		Specific Capacity 7.5										
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
6		Surface		41.1										
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
- - S -				SAND				Surface		37				
- A Y -				CRS SAND & GRAVEL				37		41.1				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6.625		SAWHILL ASTM A53B 6.625 X .280 EL 21 HT A13786 2/02 WELDED				Surface		38.1						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
6		JOHNSON SS 12 SLOT				38.1		41.1						
7. Grout or Other Sealing Material														
Method														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
				Surface										
9. Static Water Level														
23 ft. below ground surface														
10. Pump Test														
Pumping level 25 ft. below surface Pumping at 15 GP for 2 Hrs. Pumping Method ?														
11. Well Is														
18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller														
RR								Lic #		Date Signed 09-04-2002				
Drill Rig Operator								Lic or Reg #		Date Signed				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		57	Building Overhang		2
			Wastewater Sump		64

Comment:

Created On: 10-02-2002

Updated On: 05-05-2020

Review Status: